

| DP [Pa] | Vol Flow Rate BEFORE INTERVENTION | DP [Pa] | Vol Flow Rate AFTER INTERVENTION |
|---------|---|---------|--|
| 6.5 | 594.7 | 8 | 637.1 |
| 10.5 | 926.0 | 11.5 | 849.5 |
| 15 | 1163.8 | 16 | 1056.8 |
| 20 | 1529.1 | 20 | 1214.8 |
| 26 | 1775.5 | 26.5 | 1495.1 |
| 29.5 | 1928.4 | 31.5 | 1656.5 |
| 35.5 | 2208.7 | 37 | 1834.9 |
| 41 | 2421.1 | 43 | 2021.8 |
| 40 | 2395.6 | 47 | 2174.7 |
| 46 | 2718.4 | 50.5 | 2276.7 |
| 51.5 | 2888.3 | 53 | 2344.6 |
| 59.5 | 3143.2 | 61 | 2548.5 |
| 60 | 3143.2 | | |
| | Before | | After |

@50Pa





| | AREA m ² | VOL m ³ | m ³ /h @ 50Pa | ACH @ 50Pa | Envelope Air leakage Index m ³ /h per m ² envelope area @ 50Pa |
|----------------------------------|------------------------|-----------------------|-----------------------------|---------------|---|
| Before Intervention June 2011 | 226.2 | 219.1 | 2832.4 | 12.9 | 12.5 |
| After Intervention March 2012 | 218.4 | 209.6 | 2257.1 | 10.8 | 10.3 |